



Collection Location 2368 sussex ln		Collector m bulkeley	Client Reference prairie view est	Accession # 2300489	
PWS ID/PWS Name IA5225326 PRAIRIE VIEW ESTATES ASSOC JOHNSON		Collected 2023-06-29 07:30	Received 2023-06-30 08:20	Project	
Report To	PRAIRIE VIEW ESTATES HOA 2368 SUSSEX LN IOWA CITY, IA 52240			Facility ID 950	Sampling Pt ID 950
				SDWA Sample Type RT - Routine	Sample Category Pb/Cu
				Sample Type Drinking Water	
				Sample Note(s) 1	

ADDITIONAL SAMPLE INFORMATION

Pb Sample Type: First Draw

RESULTS OF ANALYSIS - FINAL REPORT

TEST	RESULT (mg/L)	QUANT LIMIT	ACTION LEVEL	ANALYSIS NOTE(S)
Lead and Copper, EPA 200.8				
Lead	<0.001	0.001	0.015	
Copper	0.05	0.01	1.3	

SAMPLE AND ANALYSIS NOTES

- Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.

ANALYSIS INFORMATION

TEST	ANALYZED	SITE	RELEASED	ANALYSIS PREP
1. Lead and Copper, EPA 200.8	2023-07-03 13:49 SGB	3201	2023-07-06 11:07 BRW	

DESCRIPTION OF UNITS

mg/L = Milligrams per Liter

SITE(S) PERFORMING TESTING

3201 STATE HYGIENIC LABORATORY ANKENY, IOWA LABORATORIES COMPLEX, 2220 S ANKENY BLVD, ANKENY, IA 50023; Phone 515/725-1600; Fax 515/725-1642; Michael D. Schueller, M.S., Associate Director; Wade K. Aldous, Ph.D. (D)ABMM, Associate Director; IOWA ENVIRONMENTAL LAB ID #397

The result(s) of this report relate only to the items analyzed. Where the laboratory has not been responsible for the sampling stage the results apply only to the sample as received. This report shall not be reproduced except in full without the written approval of the laboratory. If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500.



Action Location 2242 banbury st		Collector behourek chris	Client Reference prairie view est	Accession # 2300485	
PWS ID/PWS Name IA5225326 PRAIRIE VIEW ESTATES ASSOC JOHNSON		Collected 2023-06-29 04:45	Received 2023-06-30 08:20	Project	
Report To	PRAIRIE VIEW ESTATES HOA 2368 SUSSEX LN IOWA CITY, IA 52240			Facility ID 950	Sampling Pt ID 950
				SDWA Sample Type RT - Routine	Sample Category Pb/Cu
				Sample Type Drinking Water	
				Sample Note(s) 1	

ADDITIONAL SAMPLE INFORMATION

Pb Sample Type: First Draw

RESULTS OF ANALYSIS - FINAL REPORT

<u>TEST</u>	<u>RESULT (mg/L)</u>	<u>QUANT LIMIT</u>	<u>ACTION LEVEL</u>	<u>ANALYSIS NOTE(S)</u>
Lead and Copper, EPA 200.8				
Lead	<0.001	0.001	0.015	
Copper	0.19	0.01	1.3	

SAMPLE AND ANALYSIS NOTES

1. Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.

ANALYSIS INFORMATION

<u>TEST</u>	<u>ANALYZED</u>	<u>SITE</u>	<u>RELEASED</u>	<u>ANALYSIS PREP</u>
1. Lead and Copper, EPA 200.8	2023-07-03 13:49 SGB	3201	2023-07-06 11:07 BRW	

DESCRIPTION OF UNITS

mg/L = Milligrams per Liter

SITE(S) PERFORMING TESTING

3201 STATE HYGIENIC LABORATORY ANKENY, IOWA LABORATORIES COMPLEX, 2220 S ANKENY BLVD, ANKENY, IA 50023; Phone 515/725-1600; Fax 515/725-1642; Michael D. Schueller, M.S., Associate Director; Wade K. Aldous, Ph.D. (D)ABMM, Associate Director; IOWA ENVIRONMENTAL LAB ID #397

The result(s) of this report relate only to the items analyzed. Where the laboratory has not been responsible for the sampling stage the results apply only to the sample as received. This report shall not be reproduced except in full without the written approval of the laboratory. If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500.



Collection Location 2412 banbury st		Collector everett nelson	Client Reference prairie view est	Accession # 2300486	
PWS ID/PWS Name IA5225326 PRAIRIE VIEW ESTATES ASSOC JOHNSON		Collected 2023-06-29 07:27	Received 2023-06-30 08:20	Project	
Report To	PRAIRIE VIEW ESTATES HOA 2368 SUSSEX LN IOWA CITY, IA 52240			Facility ID 950	Sampling Pt ID 950
				SDWA Sample Type RT - Routine	Sample Category Pb/Cu
				Sample Type Drinking Water	
				Sample Note(s) 1	

ADDITIONAL SAMPLE INFORMATION

Pb Sample Type: First Draw

RESULTS OF ANALYSIS - FINAL REPORT

TEST	RESULT (mg/L)	QUANT LIMIT	ACTION LEVEL	ANALYSIS NOTE(S)
Lead and Copper, EPA 200.8				
Lead	<0.001	0.001	0.015	
Copper	0.25	0.01	1.3	

SAMPLE AND ANALYSIS NOTES

1. Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.

ANALYSIS INFORMATION

TEST	ANALYZED	SITE	RELEASED	ANALYSIS PREP
1. Lead and Copper, EPA 200.8	2023-07-03 13:49 SGB	3201	2023-07-06 11:07 BRW	

DESCRIPTION OF UNITS

mg/L = Milligrams per Liter

SITE(S) PERFORMING TESTING

3201 STATE HYGIENIC LABORATORY ANKENY, IOWA LABORATORIES COMPLEX, 2220 S ANKENY BLVD, ANKENY, IA 50023; Phone 515/725-1600; Fax 515/725-1642; Michael D. Schueller, M.S., Associate Director; Wade K. Aldous, Ph.D. (D)ABMM, Associate Director; IOWA ENVIRONMENTAL LAB ID #397

The result(s) of this report relate only to the items analyzed. Where the laboratory has not been responsible for the sampling stage the results apply only to the sample as received. This report shall not be reproduced except in full without the written approval of the laboratory. If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500.



Collection Location 1304 devon dr		Collector sondergard mike	Client Reference prairie view est	Accession # 2300487	
PWS ID/PWS Name IA5225326 PRAIRIE VIEW ESTATES ASSOC JOHNSON		Collected 2023-06-29 08:27	Received 2023-06-30 08:20	Project	
Report To	PRAIRIE VIEW ESTATES HOA 2368 SUSSEX LN IOWA CITY, IA 52240			Facility ID 950	Sampling Pt ID 950
				SDWA Sample Type RT - Routine	Sample Category Pb/Cu
				Sample Type Drinking Water	
				Sample Note(s) 1	

ADDITIONAL SAMPLE INFORMATION

Pb Sample Type: First Draw

RESULTS OF ANALYSIS - FINAL REPORT

TEST	RESULT (mg/L)	QUANT LIMIT	ACTION LEVEL	ANALYSIS NOTE(S)
Lead and Copper, EPA 200.8				
Lead	<0.001	0.001	0.015	
Copper	0.16	0.01	1.3	

SAMPLE AND ANALYSIS NOTES

1. Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.

ANALYSIS INFORMATION

TEST	ANALYZED	SITE	RELEASED	ANALYSIS PREP
1. Lead and Copper, EPA 200.8	2023-07-03 13:49 SGB	3201	2023-07-06 11:07 BRW	

DESCRIPTION OF UNITS

mg/L = Milligrams per Liter

SITE(S) PERFORMING TESTING

3201 STATE HYGIENIC LABORATORY ANKENY, IOWA LABORATORIES COMPLEX, 2220 S ANKENY BLVD, ANKENY, IA 50023; Phone 515/725-1600; Fax 515/725-1642; Michael D. Schueller, M.S., Associate Director; Wade K. Aldous, Ph.D. (D)ABMM, Associate Director; IOWA ENVIRONMENTAL LAB ID #397

The result(s) of this report relate only to the items analyzed. Where the laboratory has not been responsible for the sampling stage the results apply only to the sample as received. This report shall not be reproduced except in full without the written approval of the laboratory. If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500.



Collection Location 2324 kent ct		Collector hart rob	Client Reference prairie view est	Accession # 2300488	
PWS ID/PWS Name IA5225326 PRAIRIE VIEW ESTATES ASSOC JOHNSON		Collected 2023-06-29 06:00	Received 2023-06-30 08:20	Project	
Report To	PRAIRIE VIEW ESTATES HOA 2368 SUSSEX LN IOWA CITY, IA 52240			Facility ID 950	Sampling Pt ID 950
				SDWA Sample Type RT - Routine	Sample Category Pb/Cu
				Sample Type Drinking Water	
				Sample Note(s) 1	

ADDITIONAL SAMPLE INFORMATION

Pb Sample Type: First Draw

RESULTS OF ANALYSIS - FINAL REPORT

<u>TEST</u>	<u>RESULT (mg/L)</u>	<u>QUANT LIMIT</u>	<u>ACTION LEVEL</u>	<u>ANALYSIS NOTE(S)</u>
Lead and Copper, EPA 200.8				
Lead	<0.001	0.001	0.015	
Copper	0.21	0.01	1.3	

SAMPLE AND ANALYSIS NOTES

- Upon arrival, sample met container and preservation requirements for the analysis requested. Please review carefully your sample results for additional analyte comments or method exceptions.

ANALYSIS INFORMATION

<u>TEST</u>	<u>ANALYZED</u>	<u>SITE</u>	<u>RELEASED</u>	<u>ANALYSIS PREP</u>
1. Lead and Copper, EPA 200.8	2023-07-03 13:49 SGB	3201	2023-07-06 11:07 BRW	

DESCRIPTION OF UNITS

mg/L = Milligrams per Liter

SITE(S) PERFORMING TESTING

3201 STATE HYGIENIC LABORATORY ANKENY, IOWA LABORATORIES COMPLEX, 2220 S ANKENY BLVD, ANKENY, IA 50023; Phone 515/725-1600; Fax 515/725-1642; Michael D. Schueller, M.S., Associate Director; Wade K. Aldous, Ph.D. (D)ABMM, Associate Director; IOWA ENVIRONMENTAL LAB ID #397

The result(s) of this report relate only to the items analyzed. Where the laboratory has not been responsible for the sampling stage the results apply only to the sample as received. This report shall not be reproduced except in full without the written approval of the laboratory. If you have any questions, please call Client Services at 800/421-IOWA (4692) or 319/335-4500.